

## Panel feed-through terminal block - HDFKV 10 GNYE - 0709291


Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (<http://phoenixcontact.com/download>)



Panel feed-through terminal block, Connection method: Screw connection, Number of positions: 1, Color: green-yellow

The figure shows a version of the article

### Key Commercial Data

Packing unit	1 pc
Minimum order quantity	50 pc
GTIN	 4 017918 005016
Weight per Piece (excluding packing)	21.29 g
Custom tariff number	85369010
Country of origin	Greece

### Technical data

#### General

Color	green-yellow
Number of positions	1

#### Connection data

Connection method	Screw connection
-------------------	------------------

#### Standards and Regulations

Connection in acc. with standard	CSA
----------------------------------	-----

### Classifications

#### eCl@ss

eCl@ss 4.0	27141131
eCl@ss 4.1	27141131

# Panel feed-through terminal block - HDFKV 10 GNYE - 0709291

## Classifications

### eCl@ss

eCl@ss 5.0	27141134
eCl@ss 5.1	27141134
eCl@ss 6.0	27141134
eCl@ss 7.0	27141134
eCl@ss 8.0	27141134
eCl@ss 9.0	27141134

### ETIM

ETIM 2.0	EC001283
ETIM 3.0	EC001283
ETIM 4.0	EC001283
ETIM 5.0	EC001283

### UNSPSC

UNSPSC 6.01	30211811
UNSPSC 7.0901	39121410
UNSPSC 11	39121410
UNSPSC 12.01	39121410
UNSPSC 13.2	39121410

## Approvals

### Approvals

---

#### Approvals

CSA / UL Recognized / KEMA-KEUR / PRS / IECCE CB Scheme / EAC / EAC

---

#### Ex Approvals

---


#### Approvals submitted


---


#### Approval details

# Panel feed-through terminal block - HDFKV 10 GNYE - 0709291


## Approvals

CSA 	
mm <sup>2</sup> /AWG/kcmil	22-6
Nominal current I <sub>N</sub>	65 A
Nominal voltage U <sub>N</sub>	300 V

UL Recognized 		
	B	D
mm <sup>2</sup> /AWG/kcmil	24-6	24-6

KEMA-KEUR 	
mm <sup>2</sup> /AWG/kcmil	10
Nominal current I <sub>N</sub>	57 A
Nominal voltage U <sub>N</sub>	250 V

PRS
-----

IECEE CB Scheme 	
mm <sup>2</sup> /AWG/kcmil	10
Nominal current I <sub>N</sub>	57 A
Nominal voltage U <sub>N</sub>	250 V

EAC
-----

EAC
-----