

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (http://phoenixcontact.com/download)



Bolt connection terminal block, Connection type: Bolt connection, Cross section: 0.1 mm² - 6 mm², AWG: 26 - 10, Nominal current: 41 A, Nominal voltage: 1000 V, Length: 66 mm, Width: 16.3 mm, Color: gray, Assembly: NS 35/7,5, NS 35/15

Product Features

- The special clamping nuts can be actuated with a normal screwdriver
- Easy bridging and potential distribution using the patented plug-in bridges from the CLIPLINE complete system
- The screws are secured against loosening by captive spring-loaded spacers
- Quick and easy connection thanks to hinged cover flaps which hold the clamping nuts captive. When the flaps are open, the connection bolt is freely accessible and the cable lugs can be hooked in; after closing and engaging the flaps
- Large-surface labeling options in the terminal center and above the terminal points
- The hinged cover cover the live metal parts including the insulated cable lugs in the clamping area so that they are touch proof
- The use of the switching lock effectively prevents unintentional switching
- Testing with the standardized test adapters and test plugs of the CLIPLINE complete system
- Tested for railway applications



Key Commercial Data

Packing unit	1 pc
Minimum order quantity	50 pc
Weight per Piece (excluding packing)	39.6 g
Custom tariff number	85369010
Country of origin	China

Technical data

General

Note	Note: the BE-RT path extension is to be used for non-insulated cable lugs (see accessories).
Number of levels	1



Technical data

General

Number of connections	2	
Potentials	1	
Nominal cross section	6 mm ²	
Color	gray	
Insulating material	РА	
Flammability rating according to UL 94	V0	
Area of application	Railway industry	
	Machine building	
	Plant engineering	
	Process industry	
Rated surge voltage	8 kV	
Degree of pollution	3	
Overvoltage category	III	
Insulating material group	1	
Maximum load current	41 A (with 6 mm ² conductor cross section)	
Nominal current I _N	41 A	
Nominal voltage U_N	1000 V (Rated voltage for open disconnect point 500 V)	
Open side panel	Yes	
Result of surge voltage test	Test passed	
Surge voltage test setpoint	9.8 kV	
Result of power-frequency withstand voltage test	Test passed	
Power frequency withstand voltage setpoint	2.2 kV	
Result of the test for mechanical stability of terminal points (5 x conductor connection)	Test passed	
Result of tight fit on support	Test passed	
Tight fit on carrier	NS 35	
Setpoint	5 N	
Result of voltage-drop test	Test passed	
Requirements, voltage drop	≤ 3.2 mV	
Result of temperature-rise test	Test passed	
Short circuit stability result	Test passed	
Conductor cross section short circuit testing	6 mm²	
Short-time current	0.72 kA	
Result of thermal test	Test passed	
Proof of thermal characteristics (needle flame) effective duration	30 s	
Relative insulation material temperature index (Elec., UL 746 B)	130 °C	
Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21))	130 °C	



Technical data

General

Static insulating material application in cold	-60 °C	
Dimensions		
Width	16.3 mm	
End cover width	2.2 mm	
Length	66 mm	
Height NS 35/7,5	51 mm	
Height NS 35/15	58.5 mm	

Connection data

Connection bolts
Bolt connection
IEC 60947-7-1
0.1 mm ²
6 mm ²
26
10
0.1 mm ²
6 mm ²
26
10
DIN 46 234
0.5 mm ²
6 mm ²
5.3 mm
10 mm
5 mm
DIN 46237
1 mm ²
6 mm ²
5.3 mm
10 mm
5 mm
M5
2.5 Nm
3 Nm
CUL



Technical data

Standards and Regulations

	IEC 60947-7-1
	DIN 46 234
	DIN 46237
Flammability rating according to UL 94	V0

Classifications

eCl@ss

eCl@ss 4.0	27141120
eCl@ss 4.1	27141120
eCl@ss 5.0	27141120
eCl@ss 5.1	27141120
eCl@ss 6.0	27141120
eCl@ss 7.0	27141120
eCl@ss 8.0	27141120
eCl@ss 9.0	27141120

ETIM

ETIM 2.0	EC000897
ETIM 3.0	EC000897
ETIM 4.0	EC000897
ETIM 5.0	EC000897

UNSPSC

UNSPSC 6.01	30211811
UNSPSC 7.0901	39121410
UNSPSC 11	39121410
UNSPSC 12.01	39121410
UNSPSC 13.2	39121410

Approvals

Approvals

Approvals

UL Recognized / VDE Zeichengenehmigung / cUL Recognized / ABS / IECEE CB Scheme / EAC / EAC / cULus Recognized



Bolt connection terminal block - RT 5 - 3049026

Approvals

Ex Approvals

ATEX / IECEx / EAC Ex

Approvals submitted

Approval details

	В	C
Nominal current IN	30 A	30 A
Nominal voltage UN	600 V	600 V

mm²/AWG/kcmil	0.14-6
Nominal current IN	41 A
Nominal voltage UN	1000 V

cUL Recognized		
	В	С
Nominal current IN	30 A	30 A
Nominal voltage UN	600 V	600 V

ABS

IECEE CB Scheme

EAC



Approvals

EAC

cULus Recognized

Drawings

Circuit diagram

o**---**0

Phoenix Contact 2016 $\ensuremath{\mathbb{C}}$ - all rights reserved http://www.phoenixcontact.com

05/10/2016 Page 6 / 6