

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (http://phoenixcontact.com/download)



Feed-through terminal block, Connection method: Push-in connection, Cross section: 0.14 mm² - 4 mm², AWG: 26 - 12, Width: 5.2 mm, Color: gray, Mounting type: NS 35/7,5, NS 35/15

Product Features

- 2, 3, and 4-conductor terminal blocks with the same shape
- Ground terminal blocks of the same shape are available
- The PTS 2,5, which is equipped with four bridge shafts, offers a wide range of potential bridging options
- Angled conductor entry for use in flat terminal boxes
- Large space saving when used in concealed wiring systems



Key Commercial Data

| Packing unit | 1 pc |
|--------------------------------------|----------|
| Minimum order quantity | 50 pc |
| Weight per Piece (excluding packing) | 8.0 g |
| Custom tariff number | 85369010 |
| Country of origin | Poland |

Technical data

General

| Number of levels | 1 |
|--|---------|
| Number of connections | 3 |
| Nominal cross section | 2.5 mm² |
| Color | gray |
| Insulating material | PA |
| Flammability rating according to UL 94 | V0 |
| Rated surge voltage | 8 kV |
| Overvoltage category | III |



Technical data

General

| Insulating material group | I |
|---|---|
| Connection in acc. with standard | IEC 60947-7-1 |
| Maximum load current | 28 A (with 4 mm² conductor cross section) |
| Nominal current I _N | 24 A |
| Nominal voltage U _N | 800 V |
| Open side panel | Yes |
| Shock protection test specification | DIN EN 50274 (VDE 0660-514):2002-11 |
| Back of the hand protection | guaranteed |
| Finger protection | guaranteed |
| Result of surge voltage test | Test passed |
| Surge voltage test setpoint | 9.8 kV |
| Result of power-frequency withstand voltage test | Test passed |
| Power frequency withstand voltage setpoint | 2 kV |
| Result of the test for mechanical stability of terminal points (5 x conductor connection) | Test passed |
| Result of bending test | Test passed |
| Bending test rotation speed | 10 rpm |
| Bending test turns | 135 |
| Bending test conductor cross section/weight | 0.14 mm² / 0.2 kg |
| | 2.5 mm² / 0.7 kg |
| | 4 mm² / 0.9 kg |
| Tensile test result | Test passed |
| Conductor cross section tensile test | 0.14 mm² |
| Tractive force setpoint | 10 N |
| Conductor cross section tensile test | 2.5 mm² |
| Tractive force setpoint | 50 N |
| Conductor cross section tensile test | 4 mm² |
| Tractive force setpoint | 60 N |
| Result of tight fit on support | Test passed |
| Tight fit on carrier | NS 35 |
| Setpoint | 1 N |
| Result of voltage-drop test | Test passed |
| Requirements, voltage drop | ≤ 3.2 mV |
| Result of temperature-rise test | Test passed |
| Short circuit stability result | Test passed |
| Conductor cross section short circuit testing | 2.5 mm² |
| Short-time current | 0.3 kA |
| | |



Technical data

General

| Conductor cross section short circuit testing | 4 mm² |
|---|---|
| Short-time current | 0.48 kA |
| Result of aging test | Test passed |
| Ageing test for screwless modular terminal block temperature cycles | 192 |
| Result of thermal test | Test passed |
| Proof of thermal characteristics (needle flame) effective duration | 30 s |
| Oscillation, broadband noise test result | Test passed |
| Test specification, oscillation, broadband noise | DIN EN 50155 (VDE 0115-200):2008-03 |
| Test spectrum | Service life test category 1, class B, body mounted |
| Test frequency | $f_1 = 5 \text{ Hz to } f_2 = 150 \text{ Hz}$ |
| ASD level | 0.02 g²/Hz |
| Acceleration | 0,8 g |
| Test duration per axis | 5 h |
| Test directions | X-, Y- and Z-axis |
| Shock test result | Test passed |
| Test specification, shock test | DIN EN 50155 (VDE 0115-200):2008-03 |
| Shock form | Half-sine |
| Acceleration | 5 g |
| Shock duration | 30 ms |
| Number of shocks per direction | 3 |
| Test directions | X-, Y- and Z-axis (pos. and neg.) |
| Relative insulation material temperature index (Elec., UL 746 B) | 130 °C |
| Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) | 130 °C |

Dimensions

| Width | 5.2 mm |
|------------------|---------|
| End cover width | 2.2 mm |
| Length | 49 mm |
| Height NS 35/7,5 | 43 mm |
| Height NS 35/15 | 50.5 mm |

Connection data

| Connection method | Push-in connection |
|------------------------------------|--------------------|
| Connection in acc. with standard | IEC 60947-7-1 |
| Conductor cross section solid min. | 0.14 mm² |
| Conductor cross section solid max. | 4 mm² |
| Conductor cross section AWG min. | 26 |
| Conductor cross section AWG max. | 12 |



Technical data

Connection data

| Conductor cross section flexible min. | 0.14 mm² |
|---|------------|
| Conductor cross section flexible max. | 2.5 mm² |
| Min. AWG conductor cross section, flexible | 26 |
| Max. AWG conductor cross section, flexible | 14 |
| Conductor cross section flexible, with ferrule without plastic sleeve min. | 0.14 mm² |
| Conductor cross section flexible, with ferrule without plastic sleeve max. | 2.5 mm² |
| Conductor cross section flexible, with ferrule with plastic sleeve min. | 0.14 mm² |
| Conductor cross section flexible, with ferrule with plastic sleeve max. | 2.5 mm² |
| 2 conductors with same cross section, stranded, TWIN ferrules with plastic sleeve, max. | 0.5 mm² |
| Stripping length | 8 mm 10 mm |
| Internal cylindrical gage | A3 |
| Stripping length | 8 mm 10 mm |

Standards and Regulations

| Connection in acc. with standard | CSA |
|--|---------------|
| | IEC 60947-7-1 |
| Flammability rating according to UL 94 | V0 |

Classifications

eCl@ss

| eCl@ss 4.0 | 27141121 |
|------------|----------|
| eCl@ss 4.1 | 27141121 |
| eCl@ss 5.0 | 27141120 |
| eCl@ss 5.1 | 27141120 |
| eCl@ss 6.0 | 27141120 |
| eCl@ss 7.0 | 27141120 |
| eCl@ss 8.0 | 27141120 |
| eCl@ss 9.0 | 27141120 |

ETIM

| ETIM 2.0 | EC000897 |
|----------|----------|
| ETIM 3.0 | EC000897 |
| ETIM 4.0 | EC000897 |
| ETIM 5.0 | EC000897 |

UNSPSC

| UNSPSC 6.01 | 30211811 |
|-------------|----------|



Classifications

UNSPSC

| UNSPSC 7.0901 | 39121410 |
|---------------|----------|
| UNSPSC 11 | 39121410 |
| UNSPSC 12.01 | 39121410 |
| UNSPSC 13.2 | 39121410 |

Approvals

| Α | n | n | rn | ١., | 2 | c |
|---|---|---|----|-----|---|---|
| | | | | | | |

Approvals

 $\label{local_prop_local_prop_local} \mbox{UL Recognized / LR / RS / ABS / NK / IECEE CB Scheme / CSA / BV / EAC / NK / EAC / cULus Recognized \\ \mbox{Recognized}$

Ex Approvals

Approvals submitted

Approval details

| UL Recognized 3 | | | | |
|------------------------|-------|-------|--|--|
| | В | С | | |
| mm²/AWG/kcmil | 26-12 | 26-12 | | |
| Nominal current IN | 20 A | 20 A | | |
| Nominal voltage UN | 600 V | 600 V | | |

| VDE Zeichengenehmigung 📤 | | | | |
|--------------------------|---------|--|--|--|
| | | | | |
| mm²/AWG/kcmil | 0.2-2.5 | | | |
| Nominal current IN | 24 A | | | |
| Nominal voltage UN | 800 V | | | |



Approvals

| cUL Recognized 🔊 | | | | | |
|---|-------|---------|-------|-------|--|
| | В | | С | | |
| mm²/AWG/kcmil | 26-12 | | | | |
| Nominal current IN | 20 A | | | | |
| Nominal voltage UN | 600 V | | 600 V | | |
| | | | · | | |
| LR | | | | | |
| DC. | | | | | |
| RS | | | | | |
| ABS | | | | | |
| AllZ | | | | | |
| NK | | | | | |
| IECEE CB Scheme CB | | | | | |
| mm²/AWG/kcmil | | 0.2-2.5 | | | |
| Nominal voltage UN | | 800 V | | | |
| CSA 👀 | | | | | |
| | В | | С | | |
| mm²/AWG/kcmil | 26-12 | | 26-12 | | |
| Nominal current IN | 20 A | | 20 A | | |
| | 600 V | | 600 V | 600 V | |
| | | | | | |
| Nominal voltage UN | | | | | |
| Nominal current IN Nominal voltage UN BV EAC | | | | | |
| Nominal voltage UN | | | | | |



Approvals

| EAC | |
|--------------------|--|
| | |
| | |
| cULus Recognized c | |
| octo roogimed • • | |

Drawings

Circuit diagram

O-O---O

Phoenix Contact 2016 @ - all rights reserved http://www.phoenixcontact.com